

# Certificate of Conformity

Registered No.:  
**COCPPV04064/22B-01**

File reference  
PVP04064/22B-01

Test report No.  
TRPVP04064/22B/01

Date of issue  
2021-06-21

On the basis of the tests undertaken, the samples of the below product(s) have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out:

**Applicant:** **Xiamen Kehua Digital Energy Tech Co., Ltd**  
Room 208-38, Hengye Building, No. 100 Xiangxing Road, Torch High-tech Zone (Xiang'an) Industrial Zone, Xiamen, China.

**Manufacturer:** **Xiamen Kehua Digital Energy Tech Co., Ltd**  
Room 208-38, Hengye Building, No. 100 Xiangxing Road, Torch High-tech Zone (Xiang'an) Industrial Zone, Xiamen, China.

**Factory:** **ZHANGZHOU KEHUA ELECTRIC TECHNOLOGY CO., LTD**  
NO.11, JINXING ROAD, XIANGCHENG DISTRICT, ZHANGZHOU CITY, FUJIAN PROVINCE, CHINA

**Product:** PV Grid-tied Inverter

**Type designation:** SPI12K-B X2, SPI15K-B X2,  
SPI25K-B X2, SPI30K-B X2

**Certification program:** BOS-P-01 Rev. 00

**Certification fundamental(s):** IEC 61683:1999

See test report for detailed information.

This document is based on the evaluation of the samples of the above mentioned product(s). It does not imply an assessment of the mass-production of the product(s), and it does not permit the use of a TÜV NORD mark. The holder of this document may use it in connection with the related test report(s).



Renewable Energy

BOS-T-015 COC



中国认可  
产品  
**PRODUCT**  
**CNAS C183-P**

Page 1 of 1

TÜV NORD (HANGZHOU) CO., LTD.  
Member of TÜV NORD Group  
Tel: +86-571-85386989  
Fax: +86-571-85386986  
www.tuv-nord.com/cn  
P.R. China

Version 1.3